

THE USE OF THESE DRAWINGS AND SPECIFICATIONS IS LIMITED TO THE PROJECT AND SITE FOR WHICH THEY WERE PREPARED. ANY REUSE, REPRODUCTION OR PUBLICATION IN WHOLE OR IN PART IS PROHIBITED. THE USER OF THESE DRAWINGS AND SPECIFICATIONS ASSUMES ALL LIABILITY FOR THE DESIGN, CONSTRUCTION, OPERATION AND MAINTENANCE OF THE SYSTEMS SHOWN HEREON. THE USER OF THESE DRAWINGS AND SPECIFICATIONS SHALL CONSULT WITH THESE DRAWINGS AND SPECIFICATIONS FOR THE DESIGN, CONSTRUCTION, OPERATION AND MAINTENANCE OF THE SYSTEMS SHOWN HEREON. THE USER OF THESE DRAWINGS AND SPECIFICATIONS SHALL CONSULT WITH THESE DRAWINGS AND SPECIFICATIONS FOR THE DESIGN, CONSTRUCTION, OPERATION AND MAINTENANCE OF THE SYSTEMS SHOWN HEREON.





1 RADIANT HEATING PLAN
SCALE: 1/4" = 1'-0"

SHEET NOTES

1. HEAT SOURCE AND CONTROLS COORD EXACT LOCATION OF EQUIPMENT WITH ARCHITECT AND ALL TRADES BEFORE INSTALLATION OR ORDERING EQUIPMENT.
2. PROVIDE A MEANS OF DISCONNECT ADJACENT TO AND WITHIN SITE OF THE EQUIPMENT PER 2010 CMC 309.0 AND A 120V RECEPTACLE WITHIN 25' OF EQUIPMENT, NOT CONNECTED TO THE DISCONNECT.
3. NOTE: PROVIDE MANUFACTURER'S INSTALLATION SPECIFICATIONS AND REQUIREMENTS ON SITE FOR FIELD INSPECTION
4. PRESSURE RELIEF AND BACKFLOW PREVENTER FOR WATER HEATER PER 2010 CPC 608.5
5. HEAT SOURCE VENT PIPING AND TERMINATION TO BE DETERMINED PER OPTIONS ON HEAT SOURCE VENTING SHEET. COORD WITH GENERAL AND PROPOSE OPTIONS TO BE APPROVED BY OWNER AND ARCHITECT.
6. PROVIDE WALL OR FLOOR SINK (INDIRECT WASTE) FOR WATER HEATER CONDENSATE REMOVAL AND PRESSURE RELIEF

REVISIONS: BY:

MONTEREY ENERGY GROUP
Consulting Mechanical Engineering
227 Forest Avenue, Suite 5, Pacific Grove, CA 93950
831-372-8328 VOICE
831-372-4613 FAX
www.montereyenergygroup.com
info@meeg4.com



**TOMLIN
RESIDENCE**
18 LA BANCHERA
CARMEL VALLEY, CA 93924

**RADIANT
HEATING PLAN**

DATE: 01/13/2014
SCALE: AS NOTED
DRAWN: MEG
CHECKED:
FILE NAME:

SHEET:
M2.1
SHEET OF SHEETS